



cc: Admin  
DPW


State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION

CHRIS CHRISTIE  
GOVERNOR

BOB MARTIN  
Commissioner

KIM GUADAGNO  
LT. GOVERNOR



Mail Code 401-04Q

Division of Water Supply & Geoscience  
Water System Operations Element

Bureau of Water System Engineering  
401 E. State Street - P.O. Box 420  
Trenton, New Jersey 08625-0420

Tel #: (609) 292-2957 - Fax #: (609) 633-1495  
<http://www.nj.gov/dep/watersupply/>

December 12, 2014

New Jersey American Water Company  
P.O. Box 49  
Washington, NJ 07882

Dear Water Purveyor:

Enclosed is a simplified water main extension permit dated December 12, 2014 issued to you pursuant to the New Jersey Safe Drinking Water Act, N.J.S.A. 58:12A, and in consideration of your application dated August 29, 2014 and signed by Nick Pinto, Manager - Field Operations.

Your permit is for:

- ◆ Installation of 260 L.F. of 4 and 8 inch DIP domestic and fire service laterals and relocation of 415 L.F. of a 16 inch DIP line to serve Fratelli Beretta USA, a proposed 182,440 S.F. warehouse, assembly and office facility for the preparation of dried cured meats; located in the Township of Mount Olive (750 Clark Drive, Block # 102, Lot # 11), County of Morris, New Jersey; and
- ◆ The distribution of water for potable purposes from said works.

Your attention is directed to both the **specific and general** conditions of the aforementioned permit, in particular, **condition No. 6**. Enclosed with this permit is the Construction Completion Certification (CCC). The CCC **must** be submitted as required by the Submittal Action Requirements in the attached permit conditions. If the facility is not completed within the specified time allotment, an "Extension of Time" shall be requested at least ninety (90) days prior to the permit expiration date to allow for review and approval. No extension of time will be granted to an expired permit. Should you have any questions about this permit, please contact Laura Norkute at (609) 292-2957. When contacting the Department regarding this permit, please reference the Permit No. and PWSID No. provided herein.

Sincerely,

Steven Pudney, C.Eng., MICE  
Section Chief – Engineering North  
Bureau of Water System Engineering

**PWSID NO.: NJ1427017 WCP140002**

Enclosures

cc: Gregory Ploussas, Chester, Ploussas, Lisowsky Partnership, LLC  
Mayor and Council of Mount Olive  
Laura Norkute, BWSE



**State of New Jersey**  
DEPARTMENT OF ENVIRONMENTAL PROTECTION

CHRIS CHRISTIE  
GOVERNOR

BOB MARTIN  
Commissioner

KIM GUADAGNO  
LT. GOVERNOR

Mail Code 401-04Q  
Division of Water Supply & Geoscience  
Water System Operations Element  
Bureau of Water System Engineering  
401 E. State Street - P.O. Box 420  
Trenton, New Jersey 08625-0420  
Tel #: (609) 292-2957 - Fax #: (609) 633-1495  
<http://www.nj.gov/dep/watersupply/>

**PERMIT\***

The New Jersey Department of Environmental Protection grants this permit in accordance with your application, attachments accompanying same application, and applicable laws and regulations. This permit is also subject to further conditions and stipulations enumerated in the supporting documents which are agreed to by the permittee upon acceptance of the permit.

<b>Permit No.</b> WCP140002	<b>Issuance Date</b>	<b>Effective Date</b>	<b>Expiration Date</b>
PWSID No. 1427017	December 12, 2014	Issuance Date	See General Condition No. 7
<b>Name and Address of Applicant</b>		<b>Location of Activity/Facility:</b>	
New Jersey American Water Company P.O. Box 49 Washington, NJ 07882		750 Clark Drive Block # 102, Lot # 11 Township of Mount Olive, Morris County	
		<b>Type of Permit</b>	<b>Statute(s):</b>
		Potable Water Supply	N.J.S.A. 58:12A-1.1 et seq.

**This permit grants permission to:**

1. Install 260 L.F. of 4 and 8 inch DIP domestic and fire service laterals and relocation of 415 L.F. of a 16 inch DIP line to serve Fratelli Beretta USA, a proposed 182,440 S.F. warehouse, assembly and office facility for the preparation of dried cured meats;
2. Operate the facilities approved by this permit and distribute water for potable purposes from said works.

**According to Simplified Water Main Extension Certification Form:**

Dated August 20, 2014, prepared by Chester, Ploussas, Lisowsky Partnership, LLC, received September 11, 2014;

**According to Plans entitled:**

Fratelli Beretta Facility  
Township of Mount Olive, Morris County

Date  
09/02/2014

Prepared By  
Chester, Ploussas, Lisowsky  
Partnership, LLC


**Additional information:** October 8, 2014 – Updated drawings and water main profile  
November 19, 2014 – Demand information

**This permit is subject to specific and general conditions contained in the following page(s):**

Continued on Requirements Page -- 1 of 2

Approved by the authority of:

Bob Martin  
Commissioner  
Department of Environmental Protection

  
Steven Pudney, C.Eng., MICE, Section Chief

\*The word permit means approval, certification, registration, etc.

## Permit Requirements

### Submittal/Action Requirements

Applicable Subject Items	Submittal/Action Type	Requirement
WCP140002, Fratelli Beretta USA (WSYT1100014)	Completed construction certification report	Within thirty days of completion of the approved facilities the permittee/engineer shall notify the Bureau of Water System Engineering of the completion date and certify that the facilities were constructed in accordance with the approved plans and specifications by returning the enclosed Construction Completion Certification (CCC). Submission shall be no later than 30 days after expiry of permit. [N.J.A.C. 7:10-11]

### Text Requirements

#### All Phases

WCP140002, Fratelli Beretta USA (WSYT1100014)

1. DISTRIBUTION SYSTEM PERMIT SPECIFIC CONDITIONS.
2. The permittee is advised that the peak daily demand associated with this approval is 0.115 MGD. [N.J.A.C. 7:10-11]
3. The permittee is advised that with this approval and previously approved water main extensions, the projected peak daily demand for this water supply will be 0.514 MGD versus a current Firm Source Capacity of 1.368 MGD. [N.J.A.C. 7:10-11]
4. The permittee is advised that the total water available from diversion privileges as set by Water Allocation Permit No. 5394 is 20 MGM and 185.4 MGY. With this approval and previously approved water main extensions, the projected peak monthly and annual demands are 13.739 MGM and 106.482 MGY. [N.J.A.C. 7:10-11]
5. This permit shall not be construed as an approval for any other future development(s) or service connections to be served by this water main extension. Separate permit applications are necessary for these development(s). [N.J.A.C. 7:10-11]
6. The permittee is advised that a backflow prevention device and physical connection permit is required pursuant to N.J.A.C. 7:10-1 et seq. on a service line that serves a facility containing an unapproved water source which may contaminate the approved water source as a result of cross-connections. Therefore the permittee shall not place such a service line into service until such time as a backflow prevention device has been installed and a physical connection permit has been obtained by the facility supplied by the service line. [N.J.A.C. 7:10-11]
7. For this permit to remain valid, the facilities approved in this permit shall be constructed and placed into service within five years from the effective date of the permit. [N.J.A.C. 7:10-11]
8. PERMIT GENERAL CONDITIONS.
9. The permit is revocable, or subject to modification or change, at any time, when in the judgment of the New Jersey Department of Environmental Protection such revocation, modification or change shall be necessary. [N.J.A.C. 7:10-11]
10. The issuance of this permit shall not be deemed to affect in any way action by the New Jersey Department of Environmental Protection on any future application. [N.J.A.C. 7:10-11]
11. The works, facilities and/or activities shown by plans and/or other engineering data, which are this day approved, subject to the conditions herewith established, shall be constructed and/or executed in conformity with such plans and/or engineering data and said conditions. [N.J.A.C. 7:10-11]
12. No change in plans or specifications shall be made without prior written permission from the Bureau of Water System Engineering. Modification requests shall be submitted on the applicable form available at [www.state.nj.us/dep/watersupply/dws\\_const.html](http://www.state.nj.us/dep/watersupply/dws_const.html). [N.J.A.C. 7:10-11]

## Text Requirements

### All Phases

WCP140002, Fratelli Beretta USA (WSYT1100014)

13. The granting of this permit shall not be construed in any way to affect the title or ownership of property, and shall not make the New Jersey Department of Environmental Protection or the State a party in any suit or question of ownership of property. [N.J.A.C. 7:10-11]
14. This permit does not waive the obtaining of Federal or other State or Local Government consent when necessary. This permit is not valid and no work shall be undertaken until such time as all other required approvals and permits have been obtained. [N.J.A.C. 7:10-11]
15. A copy of this permit shall be kept at the work site, and shall be exhibited upon the request of Department personnel. [N.J.A.C. 7:10-11]
16. In the examination of plans and/or other engineering data, the New Jersey Department of Environmental Protection does not examine the structural features of the design, such as thickness of concrete or its reinforcement, the efficiency of any electrical or mechanical equipment or apparatus, and the approval herewith given does not include these features. [N.J.A.C. 7:10-11]
17. Water distribution by said works shall at all times meet the applicable standards for quality. Additional units for the derivation, treatment and for distribution of the water shall be established if and when required by the New Jersey Department of Environmental Protection. [N.J.A.C. 7:10-11]
18. The operations of the public water facility shall be under the supervision of an operator or operators who shall possess a valid license or licenses issued by the New Jersey Department of Environmental Protection, pursuant to the provisions of the Water Supply and Wastewater Operators' Licensing Act, N.J.S.A. 58:11-64 et seq. [N.J.A.C. 7:10-11]
19. The minimum required licensing classifications shall be W-2 and T-1 or equivalent in accordance with the Licensing of Water Supply and Wastewater Treatment System Operators, N.J.A.C. 7:10A-1.1 et seq. [N.J.A.C. 7:10-11]
20. The public water facilities shall be operated in such a manner so as to be in full compliance with the New Jersey Safe Drinking Water Act Rules at N.J.A.C. 7:10-1.1 et seq. and the Water Supply Allocation Rules at N.J.A.C. 7:19-1.1 et seq. [N.J.A.C. 7:10-11]
21. The public water facilities shall be operated in such a manner as to optimize the use of all available sources of water in order to achieve and maintain compliance with Water Allocation Permit No. 5394. [N.J.A.C. 7:10-11]
22. As per N.J.A.C. 7:10-11.17, an applicant for a permit under this subchapter or any person, subject to the limitation on third party appeal rights set forth in P.L. 1993, c.359 (N.J.S.A. 52:4B-3.1 through 3.3), who believes himself or herself to be aggrieved with respect to any decision made by the Department regarding such permit application submitted pursuant to this subchapter, may contest the decision and request an adjudicatory hearing pursuant to the Administrative Procedure Act, N.J.S.A. 52:14B-1 et seq., and the Uniform Administrative Procedure Rules, N.J.A.C. 1:1 within 20 calendar days of the receipt of the permit decision. Filing details and the required form to be submitted are available at [www.state.nj.us/dep/watersupply/dws\\_const.html](http://www.state.nj.us/dep/watersupply/dws_const.html). [N.J.A.C. 7:10-12]