



(c)

cc: Admin

State of New Jersey

Department of Environmental Protection

Mail Code 401-04Q

Division of Water Supply & Geoscience

Water System Operations Element

Bureau of Water System Engineering

401 E. State Street - P.O. Box 420

Trenton, New Jersey 08625-0420

Tel #: (609) 292-2957 - Fax #: (609) 633-1495


<http://www.nj.gov/dep/watersupply/>

BOB MARTIN
Commissioner

CHRIS CHRISTIE
Governor
KIM GUADAGNO
Lt. Governor

Tim Quinn
Mount Olive Twp W D Village
P O Box 450
Mount Olive, NJ 07828

Re: **Mount Olive Twp W D Village, PWSID NO. NJ1427007
Inadequate Water Supply**



Dear Tim Quinn:

The Bureau of Water System Engineering (Bureau) has recently updated the Division of Water Supply and Geoscience's Public Water System Deficit/Surplus Table for your water system (available on the web at <http://www.nj.gov/dep/watersupply/pws.htm>). According to the Deficit/Surplus Table, the Mount Olive Twp W D Village has a deficit in at least one of its daily, monthly, or yearly limits (see attached table) as defined at N.J.A.C. 7:10-11.5(e) et seq.

As a result of this determination, this Bureau will not accept any applications for Water Main Extension or connection permits to the existing system which have an associated water demand. In addition, pursuant to N.J.A.C. 7:10-11.10(b)4, any connections or extensions to the water system with a water demand which do not need a permit from this Bureau may not be undertaken. **Until the water system deficit is corrected, no new development projects with a water demand are allowed; only water main repairs and replacement may proceed.**

Please be advised that a purveyor with insufficient capacity who is not actively pursuing additional supplies may be determined by the Department under N.J.S.A. 58:1A-14 as being "inadequate to serve its users" and be subject to a Departmental Administrative Order to "develop or acquire additional water supplies sufficient to provide that service". Therefore, it is strongly recommended that you develop a plan and schedule to provide an adequate supply. Although under certain conditions the Department may agree to allow specific projects to be connected while a water system is implementing a program by which additional, guaranteed water will become available, the Department strongly recommends that water systems take proactive steps to acquire sufficient water supply to meet anticipated growth far in advance of a project's need for water supply.

Should you have any questions concerning this matter, please contact Laura Norkute at (609) 292-2957 or by e-mail at Laura.Norkute@dep.state.nj.us. When contacting the Department, please reference the PWSID No. NJ1427007 and Letter No. WCP140001.

Sincerely,

Section Chief, Engineering South Section
Bureau of Water System Engineering

Enclosure

cc: Northern Bureau of Water Compliance and Enforcement
Mayor and Council of Mount Olive Twp

NJEMStsd_deficit_surplus_no_capacity 010914