



State of New Jersey

Department of Environmental Protection
Mail Code 401-04Q
Division of Water Supply & Geoscience
Water System Operations Element
Bureau of Water System Engineering
401 E. State Street - P.O. Box 420
Trenton, New Jersey 08625-0420
Tel #: (609) 292-2957 - Fax #: (609) 633-1495
http://www.nj.gov/dep/watersupply/

CHRIS CHRISTIE
Governor
KIM GUADAGNO
Lt. Governor

BOB MARTIN
Commissioner

March 14, 2014

Ralph Blakeslee
Netcong Water Dept
23 Maple Avenue
Netcong, NJ 07857

Re: Netcong Water Dept
Limited Firm Capacity to supply future development
PWSID NO. NJ1428001

Dear Ralph Blakeslee:

The Bureau of Water System Engineering (Bureau) recently updated the Division of Water Supply and Geoscience's Public Water System Deficit/Surplus Table for your water system (available on the web at http://www.nj.gov/dep/watersupply/pws.htm). The deficit/surplus evaluation includes supply or demand provided by bulk purchase contracts that are current and approved by the Bureau of Water Allocation and Well Permitting and specify / guarantee minimum and maximum daily, monthly and annual purchase quantities. These guaranteed amounts are applied as a credit (supply) to the receiving system and as a debit (demand) to the supplying system. According to that Table, the Netcong Water Dept has an available spare Firm Capacity of 0.50 MGD or less.

Your existing surplus Firm Capacity may be enough for many future developments or only allow a very limited number of projects. Obviously this all depends upon the amount of your surplus and the water demand associated with any future projects. The Bureau is therefore advising Netcong Water Dept that applications for Water Main Extension or connection permits with an associated demand that exceeds the system's remaining surplus firm capacity or monthly or annual allocation will not be accepted.

Should you have any questions concerning this matter, please contact Laura Norkute at (609) 292-2957 or by e-mail at Laura.Norkute@dep.state.nj.us. When contacting the Department, please reference the PWSID No. NJ1428001 and Letter No. WCP140001.

Sincerely,
Laura Norkute
Bureau of Water System Engineering

Enclosure
cc: Northern Bureau of Water Compliance and Enforcement
Mayor and Council of Mount Olive Twp, Netcong Boro, Roxbury Twp