



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION
Division of Water Quality
Municipal Finance and Construction Element
P.O. Box 420, Mail Code 401-03D
Trenton, NJ 08625-0420
Fax: (609) 633-8165
www.state.nj.us/dep/dwq

CHRIS CHRISTIE
Governor

KIM GUADAGNO
Lt. Governor

BOB MARTIN
Commissioner

Handwritten notes: done Sec: Adm. 5/27/14 sg Tim Gene B.

Fratelli Beretta USA
40 Broad Street
Carlstadt, NJ 07072



MAY 22 2014

Re: Treatment Works Approval No. 14-0026
Fratelli Beretta Facility
Mount Olive Twp, Morris County

Gentlemen:

There is enclosed a Treatment Works Approval issued to you pursuant to Title 58 of the Revised Statutes of New Jersey and in consideration of your application received on 01/29/2014 signed by Simone Bocchini, President, and Gregory Ploussas, P.E.

This approval is valid for a period of two (2) years from the issuance date, unless otherwise stated in the attached approval document. This approval shall expire unless building, installing or modifying of the treatment works has begun within the initial approval period. Treatment works approvals may be extended beyond the original two year approval date, to a maximum period of five years from the original issuance date, in accordance with the terms and conditions contained in N.J.A.C. 7:14A-22.12. A time extension request must be received by the Department prior to the permit's expiration date. Time extension requests shall be submitted to the Bureau of Construction and Connection Permits (BCCP) at the address noted in the heading of this letter.

Within 30 days of completion of the treatment works approved herein, the permittee shall submit an executed Form WQM005 (Certification for Approval by Professional Engineer) to BCCP, as indicated in the Treatment Works Approval under Part II - "General Conditions for Treatment Works Approvals", Section B. Note that for indirect dischargers, the submitted WQM005 form must also be executed by the receiving sewage treatment plant.

If you have any questions regarding the permit, please contact Robert Bowden of this office by calling (609) 984-4429.

Sincerely,
James Pontoriero, Supervisor
Bureau of Construction and Connection Permits

14-0026
Enclosure

cc: CPL Partnership, LLC
Mount Olive Twp
Musconetcong Sewerage Authority

Let's protect our earth



STATE OF NEW JERSEY
DEPARTMENT OF ENVIRONMENTAL PROTECTION
P.O. Box 402, TRENTON, NJ 08625-0402

PERMIT TO CONSTRUCT AND OPERATE* TREATMENT WORKS

**Local Agency approval required prior to operation*

The New Jersey Department of Environmental Protection grants this approval in accordance with your application, attachments accompanying same application, and applicable laws and regulation.

PERMIT NO.	ISSUANCE DATE	EXPIRATION DATE	DESIGN FLOW
14-0026	05/22/2014	05/21/2016	.065 M.G.D.

NAME AND ADDRESS OF APPLICANT
Fratelli Beretta USA
40 Broad Street
Carlstadt NJ 07072

LOCATION OF ACTIVITY
Mount Olive Twp
Morris County

This permit grants permission to:

Construct and operate 957 LF of 8" PVC sanitary sewer line along Clark Drive to serve a proposed 183,440 SF warehouse, manufacturing and office facility known as Fratelli Beretta Facility located in Mt. Olive Twp, Morris County.

According to the plans entitled:


"Amended Preliminary & Final Site Plan Fratelli Beretta Facility Lot 11, Con-4 & Lot 14, Block 102 Township of Mount Olive Morris County, New Jersey"

and according to the specifications entitled:

"Technical Specifications Installation of Sanitary Sewer Facilities 750 Clark Drive Lot 11, Con-4 & Lot 14, Block 102 Township of Mount Olive Morris County, New Jersey"

APPROVED by the Department of Environmental Protection


Shadab Ahmad, P.E.


William P. Machotka, P.E., Interim Bureau Chief
Bureau of Construction and Connection Permits

This permit is also subject to special provisos and general conditions stipulated on the attached page(s) which are agreed to by the permittee upon acceptance of the permit.

PART I

PROVISOS

A. Project Specific Provisos

1. That pursuant to N.J.A.C. 7:10A-1 et. seq., an appropriate public wastewater collection system licensed operator will be required for your system.
2. That the proper operation and maintenance of the sewer system approved herein is the sole responsibility of the OWNER AND OR APPLICANT named herein or its assignees.
3. That except as provided in N.J.A.C. 7:14A-22.4, any change in usage of the building identified in this permit, which will result in an increase in the amount of sewage generated, will require a prior approval from this office.
4. That a mapping revision or waiver must be obtained from the USEPA Region 2, 290 Broadway, New York, NY 10007-1866, prior to the initiation of construction. You may contact Grace Musumeci, Chief, Environmental Review Section, Strategic Planning and Multi-Media Programs Branch by calling (212) 637-3504 with any questions regarding this matter.
5. The issuance of this permit does not exempt the applicant of the responsibility to comply with all other permitting and regulatory requirements of the Department's Land Use Regulation Program, as applicable.

B. Custom Requirement

1. That the construction of the pretreatment facility to treat process wastewater cannot be initiated until a NJPDES/SIU permit and a General Industrial TWA are issued by the Department.
2. It is the Applicant's responsibility to obtain all Federal, State and local approvals that may be required for this project.
3. That the design flow of 0.065 M.G.D. is comprised of 1,360 G.P.D. for a 13,585 SF office, 125 G.P.D. for a warehouse with 5 employees, and 63,515 G.P.D. of process wastewater.

GENERAL CONDITIONS FOR TREATMENT WORKS APPROVALS**Section A. GENERAL CONDITIONS**

1. This permit is revocable, or subject to modification or change, at any time, when in the judgement of the Department of Environmental Protection of the State of New Jersey such revocation, modification or change shall be necessary.
2. The issuance of this permit shall not be deemed to affect in any way action by the Department of Environmental Protection of the State of New Jersey on any future application.
3. The works, facilities, and/or activities shown by plans and/or other engineering data, which are this day approved, subject to the conditions herewith established, shall be constructed and/or executed in conformity with such plans and/or engineering data and the said conditions.
4. No change in plans or specifications shall be made except with the prior written permission of the Department of Environmental Protection of the State of New Jersey.
5. The granting of this permit shall not be construed to in any way affect the title or ownership of property, and shall not make the Department of Environmental Protection or the State a party in any suit or question of property.
6. This permit does not waive the obtaining of Federal or other State or local government consent when necessary. This permit is not valid and no work shall be undertaken until such time as all other required approvals and permits have been obtained.
7. A copy of this permit shall be kept at the work site, and shall be exhibited upon request of any person.
8. No treatment unit or conveyance system may be by-passed which would result in the discharge of untreated sewage into any of the waters of the state.
9. The full responsibility for adequate design, construction and operation of the treatment works, and the full responsibility for successful collection, treatment, and discharge of pollutants shall be on the applicant.
10. The issuance of approval by the Department shall not relieve the applicant of the continuing responsibility for the successful collection, treatment, or discharge of pollutants for the continuing compliance with any applicable effluent limitations, permits, regulations, statute, or other law.
11. Review and approval is based solely upon the information contained in the application and the contents of the engineer's report as certified by the licensed professional engineer as being in compliance with the Department's Rules and Regulations.

Section B. CONSTRUCTION COMPLETION CERTIFICATION

1. Within 30 days of completion of the treatment works approved herein, the permittee shall submit two executed forms, WQM005 Certification of Approval, to the appropriate sewage treatment plant (STP) for their approval prior to operation. One executed copy approved by the receiving STP shall be forwarded to the appropriate Bureau and address noted on the cover page of this approval. Failure to submit the certification within 30 days of completion of the project may be grounds for revocation of the permit. Should partial operation be required prior to completion, approval will be under local jurisdiction.
2. In cases where the project and the receiving treatment facility are one in the same, the WQM005 Certification of Approval form must be submitted to the Bureau and address noted on the cover page of this approval within 30 days of completion of the treatment works. Failure to submit the certification within this time period may be grounds for revocation of the permit.

Section C. PERMIT EXPIRATION AND EXTENSIONS OF TIME

1. This permit shall remain in force for a period of only two years from the date of approval unless stated otherwise within the special provisos, or construction of said works has begun within the approved time frame. Interruption of construction of said works for a period of more than two years may serve as a basis for permit revocation.
2. Treatment works approvals may be extended beyond the original two year approval date, to a maximum of five years from the original issuance date, in accordance with the terms and conditions in N.J.A.C. 7:14A-22.12, unless stated otherwise within the special provisos. A time extension request must be received by the Department prior to the permit's expiration date. Requests must be submitted to the Bureau and address noted on the cover page.

Section D. ADJUDICATORY HEARING REQUESTS

1. Pursuant to N.J.A.C. 7:14A-22.24 et seq., any interested person who considers himself or herself aggrieved by this action, may, within 10 days of publication of notice of the decision in the DEP Bulletin, request a hearing by addressing a written request for such hearing to the:

Office of Legal Affairs
Attention: Adjudicatory Hearing Requests
Department of Environmental Protection
P.O. Box 420, Mail Code 401-04L
Trenton, NJ 08625-0420

Such a request should include a completed Administrative Hearing Request Checklist and Tracking form for Approvals or Denials (enclosed herein for Denials). This form is required, as DEP is the transmitting agency to the Office of Administrative Law, pursuant to N.J.A.C. 1:1-8.2.