

cc: Admin



# State of New Jersey

Department of Environmental Protection

Mail Code 401-04Q

Division of Water Supply & Geoscience

Water System Operations Element

Bureau of Water System Engineering

401 E. State Street - P.O. Box 420

Trenton, New Jersey 08625-0420

Tel #: (609) 292-2957 - Fax #: (609) 633-1495

<http://www.nj.gov/dep/watersupply/>

CHRIS CHRISTIE  
Governor  
KIM GUADAGNO  
Lt. Governor

BOB MARTIN  
Commissioner

February 18, 2015

Tim Quinn  
Mount Olive Twp Water Dept Carlton Hills  
P O Box 450  
Mount Olive, NJ 07828

**Re: Mount Olive Twp Water Dept Carlton Hills, PWSID NO. NJ1427014  
Inadequate Water Supply**

Dear Tim Quinn:

The Bureau of Water System Engineering (Bureau) has recently updated the Division of Water Supply and Geoscience's Public Water System Deficit/Surplus Table for your water system (available on the web at <http://www.nj.gov/dep/watersupply/pws.htm>). According to the Deficit/Surplus Table, the Mount Olive Twp Water Dept Carlton Hills has a deficit in at least one of its daily, monthly, or yearly limits (see attached table) as defined at N.J.A.C. 7:10-11.5(e) et seq.

As a result of this determination, this Bureau will not accept any applications for Water Main Extension or connection permits to the existing system which have an associated water demand. In addition, pursuant to N.J.A.C. 7:10-11.10(b)4, any connections or extensions to the water system with a water demand which do not need a permit from this Bureau may not be undertaken. **Until the water system deficit is corrected, no new development projects with a water demand are allowed; only water main repairs and replacement may proceed.**

Please be advised that a purveyor with insufficient capacity who is not actively pursuing additional supplies may be determined by the Department under N.J.S.A. 58:1A-14 as being "inadequate to serve its users" and be subject to a Departmental Administrative Order to "develop or acquire additional water supplies sufficient to provide that service". Therefore, it is strongly recommended that you develop a plan and schedule to provide an adequate supply. Although under certain conditions the Department may agree to allow specific projects to be connected while a water system is implementing a program by which additional, guaranteed water will become available, the Department strongly recommends that water systems take proactive steps to acquire sufficient water supply to meet anticipated growth far in advance of a project's need for water supply.

Should you have any questions concerning this matter, please contact Laura Norkute at (609) 292-2957 or by e-mail at [Laura.Norkute@dep.nj.gov](mailto:Laura.Norkute@dep.nj.gov). When contacting the Department, please reference the PWSID No. NJ1427014 and Letter No. WCP150001.

Sincerely,

Section Chief, Engineering North Section  
Bureau of Water System Engineering

Enclosure

cc: Northern Bureau of Water Compliance and Enforcement  
Mayor and Council of Mount Olive Twp

NJEMS\sd\_deficit\_surplus\_no\_capacity 021815

PWSID #: 1427014

County: Morris

Name: Mount Olive Township Water Department - Carlton Hills

Last Updated: 12/02/14

Updated By: LN

Firm Capacity: 0.000 MGD

**Allocation Limits:**

(Monthly) 2.977 MGM  
(Yearly) 28.685 MGY

**Contract Limits:**

(Monthly) N/A MGM  
(Yearly) N/A MGY

**Total Limits:**

(Monthly) 2.977 MGM  
(Yearly) 28.685 MGY

**Five Year Peak Demand:**

(Daily) 0.064 MGD  
Month/Year 07/2012  
(Monthly) 1.925 MGM  
Month/Year 07/2012  
(Yearly) 12.187 MGY  
Year 2012

**Allocated Demand:**

(Daily) 0.000 MGD  
(Monthly) 0.000 MGM  
(Yearly) 0.000 MGY

**Deficit/Surplus:**

(Monthly) 1.052 MGM  
(Yearly) 16.498 MGY

**Total Peak Demand:**

(Daily) 0.064 MGD  
(Monthly) 1.925 MGM  
(Yearly) 12.187 MGY

**Firm-Peak Total:**

(Daily) -0.064 MGD

WAP Number: 5103

**Bureau of Safe Drinking Water Comments:**

**Bureau of Water Allocation Comments:**

Allocation split TBD (PORTION) Allocation of 530 MGY 55 MGY covers 1427002 1427005 1427006 1427007 1427008 1427012 1427014 1427015