



cc: Asman

CHRIS CHRISTIE
Governor
KIM GUADAGNO
Lt. Governor

State of New Jersey

Department of Environmental Protection
Mail Code 401-04Q
Division of Water Supply & Geoscience
Water System Operations Element
Bureau of Water System Engineering
401 E. State Street - P.O. Box 420
Trenton, New Jersey 08625-0420
Tel #: (609) 292-2957 - Fax #: (609) 633-1495
<http://www.nj.gov/dep/watersupply/>

BOB MARTIN
Commissioner

February 18, 2015

Tim Quinn
Mount Olive Twp Water Dept Tinc Farm
Box 450
Mount Olive, NJ 07828

Re: Mount Olive Twp Water Dept Tinc Farm, PWSID NO. NJ1427015
Inadequate Water Supply

Dear Tim Quinn:

The Bureau of Water System Engineering (Bureau) has recently updated the Division of Water Supply and Geoscience's Public Water System Deficit/Surplus Table for your water system (available on the web at <http://www.nj.gov/dep/watersupply/pws.htm>). According to the Deficit/Surplus Table, the Mount Olive Twp Water Dept Tinc Farm has a deficit in at least one of its daily, monthly, or yearly limits (see attached table) as defined at N.J.A.C. 7:10-11.5(e) et seq.

As a result of this determination, this Bureau will not accept any applications for Water Main Extension or connection permits to the existing system which have an associated water demand. In addition, pursuant to N.J.A.C. 7:10-11.10(b)4, any connections or extensions to the water system with a water demand which do not need a permit from this Bureau may not be undertaken. **Until the water system deficit is corrected, no new development projects with a water demand are allowed; only water main repairs and replacement may proceed.**

Please be advised that a purveyor with insufficient capacity who is not actively pursuing additional supplies may be determined by the Department under N.J.S.A. 58:1A-14 as being "inadequate to serve its users" and be subject to a Departmental Administrative Order to "develop or acquire additional water supplies sufficient to provide that service". Therefore, it is strongly recommended that you develop a plan and schedule to provide an adequate supply. Although under certain conditions the Department may agree to allow specific projects to be connected while a water system is implementing a program by which additional, guaranteed water will become available, the Department strongly recommends that water systems take proactive steps to acquire sufficient water supply to meet anticipated growth far in advance of a project's need for water supply.

Should you have any questions concerning this matter, please contact Laura Norkute at (609) 292-2957 or by e-mail at Laura.Norkute@dep.nj.gov. When contacting the Department, please reference the PWSID No. NJ1427015 and Letter No. WCP150001.

Sincerely,

Section Chief, Engineering North Section
Bureau of Water System Engineering

Enclosure

cc: Northern Bureau of Water Compliance and Enforcement
Mayor and Council of Mount Olive Twp

NJEMS\sd_deficit_surplus_no_capacity 021815

PWSID #: 1427015

County: Morris

Name: Mount Olive Township Water Department - Tinc Farm

Last Updated: 12/02/14

Updated By: LN

Firm Capacity: 0.085 MGD

Allocation Limits:

(Monthly) 6.877 MGM
(Yearly) 66.267 MGY

Contract Limits:

(Monthly) N/A MGM
(Yearly) N/A MGY

Total Limits:

(Monthly) 6.877 MGM
(Yearly) 66.267 MGY

Five Year Peak Demand:

(Daily) 0.117 MGD
Month/Year 07/2010
(Monthly) 3.521 MGM
Month/Year 07/2010
(Yearly) 25.016 MGY
Year 2010

Allocated Demand:

(Daily) 0.000 MGD
(Monthly) 0.000 MGM
(Yearly) 0.000 MGY

Deficit/Surplus:

(Monthly) 3.356 MGM
(Yearly) 41.251 MGY

Total Peak Demand:

(Daily) 0.117 MGD
(Monthly) 3.521 MGM
(Yearly) 25.016 MGY

Firm-Peak Total:

(Daily) -0.032 MGD

WAP Number: 5103 (PORTION)

Bureau of Safe Drinking Water Comments:

Bureau of Water Allocation Comments:

Allocation split TBD (PORTION) Allocation of 530 MGY 55 MGM
covers 1427002 1427005 1427006 1427007 1427008 1427012
1427014 1427015