



State of New Jersey

DEPARTMENT OF ENVIRONMENTAL PROTECTION  
ENGINEERING & CONSTRUCTION  
OFFICE OF DAM SAFETY & FLOOD CONTROL  
Mail Code 501-01A

PO Box 420, Trenton, NJ 08625-0420  
Telephone: 609-984-0859 Fax: 609-984-1908

CHRIS CHRISTIE  
Governor


KIM GUADAGNO  
Lt. Governor

BOB MARTIN  
Commissioner

AUG 03 2016

Ironbound Real Estate Holdings, LLC  
113 Greenwich Street  
Belvidere, New Jersey 07823

Re: Mine Hill Reservoir Dam (NJDEP File No. 24-23)  
Hackettstown Reservoir Dam (NJDEP File No. 24-67)  
Mount Olive Township, Morris County



Dear Dam Owner/Operator:

This is in reference to the 2016 Inspection Reports prepared on your behalf by Mary L. Paist-Goldman, P.E., of Princeton Hydro, and submitted under an April 15, 2016 cover letter.

The Upper Mine Hill Reservoir Dam has been incorrectly identified in the report as not having an assigned Bureau of Dam Safety (Bureau) file number. Please note that the dam is currently in our records under the name Hackettstown Reservoir Dam (see also above). If you wish to change the name of the Hackettstown Reservoir Dam to the Upper Mine Hill Reservoir Dam and the current Mine Hill Reservoir Dam to the Lower Mine Hill Reservoir Dam, as identified on your reports, this must be expressed in writing to the Bureau. Furthermore, the hazard classification of the Hackettstown Reservoir Dam has been revised to a Class II – Significant Hazard structure per your engineer’s recommendation.

Additionally, a copy of the Conclusion page for both dams, signed and sealed by your engineer, must be provided by **August 31, 2016**. Repeated attempts to contact your engineer directly for the documents were unsuccessful. A new Dam Safety Compliance Schedule must also be submitted by the aforementioned date and must include deadlines for the submission of all necessary documents for either the rehabilitation or removal of the Mine Hill Reservoir Dam.

Should you have any questions regarding this matter, please contact Marcus L. Roorda of this office at (609) 984-0859.

Sincerely,

John H. Moyle, P.E., Administrator  
Office of Dam Safety and Flood Control

C: Mary L. Paist-Goldman, P.E., Princeton Hydro  
Mount Olive Township Engineer & Clerk  
Morris County Engineer

V:\nhr\bdsfc\DSS\DATABASE\16letter\24023MLR16b.docx