

MOUNT OLIVE TOWNSHIP

Bid Addendum# 2

Bid#13-2016 350kW Generator & Installation at Mt. Olive Municipal Building

Attention Bidder:

Please see attached drawing "E-150 Electrical Details and Panel Schedule".

Please be advised the bid opening date has been rescheduled to **Tuesday, September 27, 2016 at 10:30AM.**

Clarifications:

1. What is the purpose of GP-LV? That panel is going to be used for the jacket heater, battery charger, motorized louvers on generator enclosure, receptacles, space heaters and lighting.
2. Is a temporary generator needed? No, the building will run on existing 80 kW generator.

Please acknowledge below that you have received the attached addendum and include with bid submission.

Name of Business:

Representative's Name:

Signature:

Date:
